



PRODUCT TECHNICAL BULLETIN

FOAM COMPATIBILITY PHOS-CHEK® 1% FLUORINE FREE FOAM CONCENTRATE & WETTING AGENT VS. COMPETITOR FOAM CONCENTRATES

INTRODUCTION

This study was undertaken to determine if PHOS-CHEK® 1% Fluorine Free Synthetic Foam Concentrate and Wetting Agent is compatible with NOVACOOOL® UEF, FIREADE® 2000, and HCT F-500. For this test, mixtures of the PHOS-CHEK 1% Fluorine Free Synthetic Foam Concentrate and Wetting Agent with the various concentrates were prepared at various ratios. These mixtures were tested for foam quality at 0.3% and 0.6% immediately after being prepared and subjected to storage at 6 °F (-21 °C) and 90 °F (32 °C) in tightly closed containers for a period of 7 days. In addition to the foam quality testing, the samples were visually inspected for any signs of incompatibility such as precipitation, haziness, gelling etc.

SAMPLE PREPARATION

Mixtures of PHOS-CHEK 1% Fluorine Free Synthetic Foam Concentrate and Wetting Agent and the various concentrates were prepared as follows:

PHOS-CHEK 1% FF (% by volume)	NOVACOOOL UEF (% by volume)	PHOS-CHEK 1% FF (% by volume)	FIREADE 2000 (% by volume)	PHOS-CHEK 1% FF (% by volume)	HCT F-500 (% by volume)
100	100	100	100	100	100
10	90	10	90	10	90
50	50	50	50	50	50
90	10	90	10	90	10

KEY

Analytical Data

- **PC1% FF:** PHOS-CHEK 1% Fluorine Free Synthetic Foam Concentrate and Wetting Agent

Foam Quality

- **ER** = Expansion Ratio
- **DT** = 25% Drain Time (minutes) of Total Volume Tested

	100 PC1% FF		10 PC1% FF / 90 NOVACOOOL UEF		50 PC1% FF / 50 NOVACOOOL UEF		90 PC1% FF / 10 NOVACOOOL UEF		100 NOVACOOOL UEF	
	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%
ER =	1.9	3.3	2.2	3.7	2.3	3.7	2.2	3.4	2.1	3.7
DT =	1.7	4.6	2.9	6.3	2.8	5.8	2.2	5.1	2.7	5.7

	100 PC1% FF		10 PC1% FF / 90 FIREADE 2000		50 PC1% FF / 50 FIREADE 2000		90 PC1% FF / 10 FIREADE 2000		100 FIREADE 2000	
	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%
ER =	1.9	3.3	1.5	2.0	1.7	2.9	1.9	3.2	1.6	2.2
DT =	1.7	4.6	1.4	2.0	1.6	3.4	1.8	4.2	1.4	2.1

	100 PC1% FF		10 PC1% FF / 90 HCT F-500		50 PC1% FF / 50 HCT F-500		90 PC1% FF / 10 HCT F-500		100 HCT F-500	
	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%	0.3%	0.6%
ER =	1.9	3.3	1.3	1.4	1.4	1.5	1.3	1.8	1.3	1.4
DT =	1.7	4.6	2.0	2.3	2.5	2.4	1.7	2.3	2.1	2.4

For more information, contact any of our worldwide Perimeter Solutions Fire Safety offices or visit www.PHOS-CHEK.com or www.Perimeter-Solutions.com

UNITED STATES
PERIMETER SOLUTIONS, LP
10667 Jersey Blvd.
Rancho Cucamonga, CA 91730
Tel: +1 800 682 3626
+1 909 983 0772
24HR: +1 909 946 7371

EMEA
PERIMETER SOLUTIONS, LP
Polígono Industrial De Baiña, Parc, 23
33682 Baiña-Mieres Asturias - Spain
Tel: +34 985 242945
24HR: +44 01202864796

ASIA PACIFIC
PERIMETER SOLUTIONS, LP
3 Charles Street
St Marys NSW 0276 - Australia
Tel: +61 2 9673 5300
24HR: +61 2 9430 6396

DISCUSSION OF RESULTS

Results show that mixing PHOS-CHEK 1% Fluorine Free Synthetic Foam Concentrate and Wetting Agent with NOVACOOOL UEF, FIREADE 2000 and HCT F-500 causes no gelling, crystal or precipitate formation. Mixing PHOS-CHEK 1% Fluorine Free Synthetic Foam Concentrate and Wetting Agent with NOVACOOOL UEF has no impact on the foaming characteristics of the diluted solutions. Mixing PHOS-CHEK 1% Fluorine Free Synthetic Foam Concentrate and Wetting Agent with FIREADE 2000 and or HCT F-500 reduces foam performance when sample is tested at 0.6%.